



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

REQUEST FOR QUOTATION No.:	1220-040-2024-005
TITLE:	NEWTON ATHLETIC PARK TENNIS COURT LIGHTING UPGRADES
ADDENDUM ISSUE DATE:	JANUARY 30, 2024
DATE:	PREFER TO RECEIVE SUBMISSION ON OR BEFORE FEBRUARY 1, 2024

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No.3 to 1220-040-2024-005 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 3 contains one (1) page.

QUESTIONS AND ANSWERS:

- Q1. Can we please extend the closing of this RFQ by one week?**
- A1. No, the City will not change the RFQ's closing date at this time.**
- Q2. Would the City accept a direct bury 1 piece concrete pole, as opposed to what is spec'd on drawings?**
- A2. No, galvanized steel poles shall be provided. Please refer to the section 16500 sports lighting supplemental specifications. Note that the Sports field lighting system shall meet off field lighting IDA criteria for community friendly outdoor sports lighting v1.3.**

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -