



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS (RFQ) **1220-040-2024-016**
 No.:

TITLE: **Supply and Delivery of Pipes and Fittings for
Watermain Projects (189A Street)**

ADDENDUM ISSUE DATE: **February 1, 2024**

REVISED DATE: **PREFER TO RECEIVE SUBMISSION ON OR
BEFORE FEBRUARY 9, 2024.**

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2024-016 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page.

REVISED DATE:

Delete Section 3 in its entirety and substitute with Section 3 below:

3. DATE

The City would prefer to receive Quotations on or before **February 9, 2024** (the "Date").

QUESTIONS AND ANSWERS:

Q1. Regarding the 300mm Tandem Restrained Couplers, my supplier has asked what the working pressure will be.

A1. **The working pressure would be between 110-115 PSI for this area.**

Q2. To ensure accurate pricing, we kindly request the precise material delivery address.

A2. **The project location is at 18949 52 Avenue Surrey BC where the material delivery would be required.**

All Addenda will become part of the Contract Documents.
