



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS (RFQ) No.: 1220-040-2024-009

TITLE: Supply and Delivery of Pipes and Fittings for Watermain Projects

ADDENDUM ISSUE DATE: February 1, 2024

REVISED DATE: **PREFER TO RECEIVE SUBMISSION ON OR BEFORE FEBRUARY 12, 2024.**

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2024-009 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page.

REVISED DATE:

Delete Section 3 in its entirety and substitute with Section 3 below:

3. DATE

The City would prefer to receive Quotations on or before **February 12, 2024** (the "Date").

QUESTION AND ANSWER:

Q1. With regards to the above mentioned RFQ and pay items 1-4, are alternates to the "Bionax" brand acceptable? Westlake/Royal Pipe offer DR18 C909 PVC pipe that meets all city specifications but is not branded 'Bionax' but rather 'Aquamax'.

A1. Yes, the alternate is acceptable. The Supplementary Master Municipal Construction Documents link in Schedule A lists both IPEX and NAPCO Royal (which is now Westlake Pipe) as the approved suppliers for PVC pipes.

All Addenda will become part of the Contract Documents.
