



PROCUREMENT SERVICES

**CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca**

ADDENDUM No. 4

REQUEST FOR QUOTATIONS (RFQ) No.: 1220-040-2024-011

TITLE: Surrey Libraires Books Sorting Machine Replacement Program (AMH)

ADDENDUM ISSUE DATE: April 30, 2024

DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE MAY 7, 2024.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 4 to 1220-040-2024-011 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 4 contains one (1) page.

1. QUESTIONS AND ANSWERS

Q1. Are you able to provide the return statistics for the external book drops (overnight average and max)?

A1. The average return for the external book drop is approximately 100 items/day.

Q2. Is the space beneath the raised floor only for cabling, or are there pipes (e.g. water/heating fluid, electrical conduit) running beneath the floor in the area of the sorter, as well?

A2. There are water pipes (heating and cooling), electrical and air plenum underneath the entire floor.

All Addenda will become part of the Contract Documents.
