



PURCHASING SECTION
13450 – 104 Avenue, Surrey, BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATION No.: 1220-040-2018-025

TITLE: REMOVAL OF EXTERIOR LEAD-BASED FINISHES

ADDENDUM ISSUE DATE: FEBRUARY 27, 2018

CLOSING DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE MARCH 6, 2018.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to RFQ 1220-040-2018-025 is hereby issued by the City. This addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page in total.

QUESTIONS & ANSWERS

- Q1. Are the lead-containing soffits to be removed/demolished or be sandblasted?
- A1. The lead-containing soffits are to be removed where possible. If it is not possible to remove them, the paint should be removed from the surface.**
- Q2. Should the grates around the buildings (air intakes, etc) be abated or should they be replaced?
- A2. All air intake grates can be removed and disposed of. City of Surrey will provide new grates.**
- Q3. Will the City of Surrey provide any night time security during the abatement?
- A3. Security will not be provided by the City of Surrey. On-site security will be the responsibility of the contractor if desired.**

- END OF ADDENDUM -

All Addenda will become part of the RFQ Documents.
