



PURCHASING SECTION
6645 – 148th Street, Surrey, B.C. V3S 3C7
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS (RFQ)

NO.: 1220-040-2013-034

TITLE: SUPPLY OF PIPE, HEADWALLS & FLOOD GATES

ADDENDUM ISSUE DATE: JUNE 20, 2013

DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE
MONDAY JUNE 24, 2013

INFORMATION FOR CONTRACTORS

The following information is provided as clarification and to answer questions raised by Contractors for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this addendum. This Addendum contains two (2) pages in total.

Information Only

- Schedule B, Section 1.(c) shall be revised as follows:
 - o "Contractor" means a contractor or a supplier whose Quotation has been accepted by the City and who is supplying the Goods under this Agreement.
- Schedule A, Section 2.2.(b) shall be revised as follows:
 - o DELETE the repeated portion of Section (b).
- Schedule A, Section 2.0 "Concrete Headwalls" on page 12 of 25 should be revised shall be revised as follows:
 - o REVISE the weight from 9,000 lbs to 8,000 lbs; and
 - o ADD the following: The Concrete Headwall shall include stop-log grooves as detailed in Figure 1.
- Schedule A, Section 2.0 – Basis of Payment shall be revised as follows:
 - o DELETE Item – 9;
 - o DELETE Item – 10; and
 - o REVISE Items 11 through 20 to be priced per each.
- Schedule A, Section 1.2 – Pipe
 - o REVISE Section (b) to read Large Diameter Polyethylene or Polypropylene Pipe; and
 - o ADD to Section (b) the following: Pipes meeting ASTM F894 may be supplied. These pipes are to meet the same pipe stiffness of 320 kPa at 5% deflection when tested in accordance with ASTM D2412 and the joints shall be water tight, meeting or exceeding the 100kPa CSA Standard B182,13 leakage requirement.

- Fees and Payments
 - o Items 1 through 6 shall be revised to read XXX mm Polypropylene, Polyethylene Pipe.
- Quotes may be provided by suppliers. Suppliers may only provide a quote for those items they are able to supply. Prices for all the items do not have to be provided for a quote to be considered. This RFQ is not intended for contractors to supply and install the materials, but simply the supply and delivery of the manufactured product they are able to supply.

Questions & Answers

Q1. In the tender documents for the City of Surrey Supply of Pipe, Headwalls & Flood Gates product it calls for Corrugated Aluminum Alloy Culvert, is this Aluminum Type 2? Is there a schedule of quantities for each product as well?

A1. Corrugated Aluminum Alloy refers to pipes made of aluminum only and does not refer to an aluminized pipe which only refers to a product “coated” with aluminum.

Q2. With regards to the above referenced subject, it appears our large diameter Weholite is not within the specification. Weholite is made to ASTM F894 and is BCMOT approved. It is considered to be a superior product compared to the steel ribbed HDPE already specified. Weholite is Canadian made whereas the steel ribbed HDPE pipe is American. Please consider a Inclusion of Weholite within this specification.

A2. See Information section of this Addendum No. 1

Q3. On page 10 of 25 line item x. There mentions standard and optional materials. Do you require (or prefer) multiple prices for standard and optional materials?

A3. Suppliers are encouraged to provide, separately, the premium prices for any optional materials which may be applicable.

Q4. Are submittal drawings required at any point in the purchasing process?

A4. Yes, submittal drawings will be required.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
