



PURCHASING SECTION
6645 – 148th Street, Surrey, B.C. V3S 3C7
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2013-064

TITLE: Supply & Installation of a Warehouse Racking System at the New Surrey Main Works Yard

ADDENDUM ISSUE DATE: October 3, 2013

DATE: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE OCTOBER 9, 2013

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information and clarifications to the RFQ for the above named project, to the extent referenced and shall become part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page in total.

- Q1. The pallet racking system that has been laid out does not match the specifications. Can the City confirm that they are looking for a similar layout utilizing 12' wide bays of pallet racking?
- A1. The drawings provided are for reference only and to provide a general idea about the overall layout. The Contractor proposed racking system shall be drawn, preferably in AutoCAD format, and laid out based on the specifications provided.
- Q2. Security fencing option - Can the City indicate how many doors, and the size of the doors required for each of the 2 fences?
- A2. Provide two (2) man door gates at the back of the warehouse racking - crossing the egress aisle. Provide two (2) larger gates at the front of the warehouse - crossing the loading zone to accommodate handling equipment such as forklifts.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
