



PURCHASING SECTION
13450 – 104 Ave, Surrey, B.C. V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM No. 3

REQUEST FOR QUOTATION (RFQ) NO.: 1220-040-2014-065
TITLE: NORTH SURREY RECREATION – UV ADDITION
ADDENDUM ISSUE DATE: October 22, 2014
PREFERRED SUBMISSION DATE: October 30, 2014

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information and clarifications to the RFQ for the above named project, to the extent referenced and shall become part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 3 contains one (1) page in total.

CLARIFICATION

Q1. Would the City consider a quote with UV Equipment manufactured by the Triogen UV Brand?

A1. See attached document 085a_036-14 – Addendum Number One (1).

Q2 Would the City consider holding a second site visit for contractors who did not attend the site visit October 15th?

A2. The City will hold a second information meeting that is open to all interested parties.

The meeting is scheduled:

LOCATION: Lobby, North Surrey Recreation Centre, 10275 City Parkway, Surrey, B.C.
DATE: October 24, 2014
TIME: 10am (local time)

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.

North Surrey Leisure Centre -
UV Addition
085a_036-14

ADDENDUM NUMBER ONE (1)

October 21, 2014
Page 1 of 1

The following addendum supersedes information contained in drawings and specifications issued for the project to the extent referenced. This Addendum forms part of the Tender Documents and is subject to all of the conditions set out in the contract conditions.

1. SPECIFICATIONS – MECHANICAL

1. **Acceptable equals for Ultra Violet Treatment system;** Hanovia and Triogen are acceptable as equal manufacturers, provided the equipment will meet following criteria;

Installation dimensions for both the reaction chamber and the control panel must allow for installation as specified. Contractor to confirm all installation dimensions with supplier.

Performance requirements must meet or exceed specified equipment.