



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM No. 4

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2015-096
TITLE: COLEBROOK ROAD CULVERT REPLACEMENT
ADDENDUM ISSUE DATE: September 11, 2015
DATE: Prefer to receive Quotations on or before
SEPTEMBER 14, 2015

INFORMATION FOR CONTRACTORS

The following information is provided for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this addendum. This Addendum No. 4 contains one (1) page in total.

Q1. Will the city pump the water out of the ditches prior to construction? If so, to what elevation?

A1. No.

Q2. Pending the answer to question 1, is it necessary to isolate and dewater each culvert following the fish salvage?

A2. The contractor is responsible to isolate, dewater and complete a salvage at each crossing.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
