



PURCHASING SECTION
13450 – 104 Avenue, Surrey, BC V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM No. 4

REQUEST FOR QUOTATIONS (RFQ) 1220-040-2015-045
NO.:
TITLE: **CHILLER PREVENTIVE MAINTENANCE SERVICES**
ADDENDUM ISSUE DATE: **APRIL 24, 2015**
REVISED DATE: **PREFER TO RECEIVE QUOTATIONS ON OR BEFORE
APRIL 29, 2015**

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide answers to questions raised by potential Contractor for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this addendum. This Addendum No. 4 contains two (2) pages in total.

1. REFER TO ITEM 3. DATE

DELETE in its entirety and SUBSTITUTE with the following:

The City would prefer to receive Quotations on or before **Wednesday, April 29, 2015**. The City's office hours are 8:30 a.m. to 4:00 p.m., Monday to Friday, except statutory holidays.

2. QUESTIONS/ANSWERS

Q1. The Cloverdale Chiller is made up of the following:
8 Modules with two (2) compressors each, 16 compressors total.

A1. That is correct.

Q2. RCMP HQ (annex): Air cooled CGAM Chiller.
This chiller is normally listed as part of the 7x per year services.
In the recent addendum it is included in the list of All-inclusive 12x per year equipment (line 32 p.3).

A2. That is correct. It should read 7x year service. Not All-inclusive.

Q3. Old Surrey City Hall (Tower):

I just noticed this chiller and cooling tower are missing from the price chart. They have always been included in the equipment list. The price chart lists Old Surrey City Hall "Civic", but does not reference the Old Surrey City Hall "Tower" (see Schedule B, Section B-2, Table 2, First line in the chart).

A3. The Tower Chiller will be decommissioned. We do not need a service for this unit.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
