



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #1

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-043
TITLE: West Village Energy Centre -
Hot Water Boilers
ADDENDUM ISSUE DATE: April 1, 2016
REVISED CLOSING DATE: prefer to receive Quotations on or
before April 13, 2016.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 1 contains one (1) page in total.

REVISED CLOSING DATE

The City would prefer to receive Quotations on or before April 13, 2016. The City's office hours are 8:30 a.m. to 4:00 p.m., Monday to Friday, except statutory holidays.

QUESTIONS AND ANSWERS:

Q.1. Are firetube boilers an acceptable product solution for the plant?

A.1. No, firetube boilers do not meet the plant's requirements.

Q.2. Please provide the project boiler floor space allocation layout.

A.2. We are unable to provide plant drawings.

END OF ADDENDUM #1

All Addenda will become part of the RFQ Documents.
