



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-043
TITLE: West Village Energy Centre -
Hot Water Boilers
ADDENDUM ISSUE DATE: April 11, 2016
REVISED CLOSING DATE: prefer to receive Quotations on or
before April 14, 2016.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains one (1) page in total.

REVISED CLOSING DATE

The City would prefer to receive Quotations on or before April 14, 2016. The City's office hours are 8:30 a.m. to 4:00 p.m., Monday to Friday, except statutory holidays.

CLARIFICATION:

Bidders shall provide sound level data in octave bands for both the boiler (all exposed surfaces) and the boiler exhaust stack. The sound level data should be presented as either sound power levels, or sound pressure levels measured in free field at a distance of minimum 1 metre from the boiler surfaces and boiler exhaust outlet. Sound measurements shall follow either standard ISO 3744 or Standard ISO 3746.

Any outstanding questions shall be submitted to purchasing@surrey.ca by April 11, 2016. If required, it is anticipated that a final addendum will be posted on April 12, 2016.

END OF ADDENDUM #2

All Addenda will become part of the RFQ Documents.
