



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #3

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-043
TITLE: West Village Energy Centre -
Hot Water Boilers
ADDENDUM ISSUE DATE: April 12, 2016
CLOSING DATE: prefer to receive Quotations on or
before April 14, 2016.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 3 contains two (2) pages in total.

QUESTIONS AND ANSWERS:

Q.1. Should the Schedule B Forms (pages 74 & 76) read 55°C for the entering water temperature?

A.1. Yes

Q.2. Is 85°C leaving water temperature for the condensing boiler acceptable? If not, what is an acceptable temperature?

A.2. Yes, 85°C is an acceptable leaving water temperature for the condensing boiler(s) only.

Q.3. Should the Schedule B Forms (pages 75 & 77) read 45°C for the entering water temperature?

A.3. Yes

Q.4. What is the actual required summer leaving water temperature?

A.4. The minimum required summer leaving temperature for the condensing boiler is 70°C.

Q.5. Boilers that are typically rated for 1103 kPa (160 psi) are supplied with a maximum 1034 kPa (150 psi) Pressure Relief Valve. Is this what you mean?

A.5. No, boilers rated for 1103 kPa must have pressure relief valves set at 1103 kPa.

Q.6. Would a 862 Kpag (125 psi) rated boiler with a 275Kpag (40psi) Relief Valve be acceptable?

A.6. No, this relief valve pressure is too low.

Q.7. Would a 862 kPag (125 psi) rated boiler with a 862 kPag (125 psi) or less Relief Valve be acceptable?

A.7. A 862 kPa rated boiler with 862 kPa pressure relief valves (no less) are acceptable for the condensing boiler(s) only.

END OF ADDENDUM #3

All Addenda will become part of the RFQ Documents.