



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM NO. 1

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-057
TITLE: SUPPLY AND INSTALL SOLAR POWERED LED
RECTANGULAR RAPID FLASHING BEACONS
(RRFB) AT 10 CROSSWALK LOCATIONS
ADDENDUM ISSUE DATE: JULY 12, 2016
CLOSING DATE: PREFER TO RECEIVE QUOTATIONS ON OR
BEFORE JULY 15, 2016.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 1 contains one (1) page in total.

Q1: Is there a possibility that the city will choose to only perform the works at a portion of the locations, or is it guaranteed that all the locations will proceed when awarded?

A1: All locations should proceed when awarded. We intend to complete 10 locations with these works.

Q2: Can we leave sidewalk panels flush with gravel and then once all locations are done in regards to civil works come back and provide the concrete/asphalt restoration?

A2: There should be a smooth surface to ensure it is accessible for wheelchairs and strollers. So temporary asphalt would be required if the time period for restoration is expected to be longer than a week.

Q3: What type of push button is a 'special pushbutton'? Is a bulldog adequate?

A3: Bulldog push button is adequate. Special crosswalk plate is required above the push button to specify it is for a warning device and not the same plate as a traffic signal. These plates will be supplied by the City.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
