



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-084
TITLE: CONSTRUCTION OF NEW STAIRS AT
NEWTON WAVE POOL
ADDENDUM ISSUE DATE: August 9, 2016
REVISED CLOSING DATE: prefer to receive Quotations on or
before: August 22, 2016

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains one (1) page in total.

NEW CLOSING DATE

The City would prefer to receive Quotations on or before **Monday, August 22, 2016**. The City's office hours are 8:30 a.m. to 4:00 p.m., Monday to Friday, except statutory holidays.

QUESTIONS AND ANSWERS:

Q1: In reference to 1.2.1vii NSF/ANSI Standard 61 in Section 06 61 00 of the Tender Specification, does this standard need to be achieved? NSF-61 is a potable water standard that is not typically used in FRP pool applications.

A1: The noted standard (NSF/ANSI Standard 61) should have been removed from the specification and is not necessary for this specific application.

END OF ADDENDUM #2