



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #5

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-084
TITLE: CONSTRUCTION OF NEW STAIRS AT
NEWTON WAVE POOL
ADDENDUM ISSUE DATE: August 25, 2016
REVISED CLOSING DATE: prefer to receive Quotations on or
before: August 29, 2016

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 5 contains one (1) page in total.

QUESTIONS AND ANSWERS:

Q1: What is the weight restriction on the existing slab?

A1: The slab is adequate to take 100 pounds per square foot.

Q2: Will there be any protection placed around the area to be demoed?

A2: No, it is the Contractor's responsibility to protect the area.

Q3: What is the largest access for bringing material in?

A3: 36 inch double doors.

Q4: The glass has been specified as 12mm tempered laminated glass with the colored interlayer. This is expensive. Easy enough to do, but I am wondering if you want to see the cost of doing the glass as 12mm tempered laminated – but clear, no colored interlayer.

A4: Please provide a separate price for the clear tempered glass as well.

END OF ADDENDUM #5

All Addenda will become part of the RFQ Documents.
