



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #6

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-084
TITLE: CONSTRUCTION OF NEW STAIRS AT
NEWTON WAVE POOL
ADDENDUM ISSUE DATE: August 26, 2016
REVISED CLOSING DATE: prefer to receive Quotations on or
before: August 29, 2016

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 6 contains one (1) page in total.

QUESTIONS AND ANSWERS:

Q1: Can we splice all the three (3) columns that support the slide due to installation?

A1: The columns that support the slides can be spliced and fully moment connected where preferred.

END OF ADDENDUM #6

All Addenda will become part of the RFQ Documents.
