



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM #2

REQUEST FOR PROPOSALS (RFP) NO.: 1220-030-2019-015
TITLE: SYNTHETIC TURF FIELD REPLACEMENT - TAMANAWIS PARK
ADDENDUM ISSUE DATE: March 15, 2019
CLOSING TIME: on or before the following date and time:
March 22, 2019, 3:00 p.m., local time

INFORMATION FOR PROPONENTS

This Addendum is issued to provide additional information to the RFP for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent not being familiar with this Addendum. This Addendum No. 2 contains two (2) pages in total.

QUESTIONS AND ANSWERS:

Q1: What is the current slope of both fields?

A1: Both fields are flat.

Q2: Can you tell us more about the existing watering situation? Does the existing/planned irrigation system meet the FIH Global Certification requirements?

A2: Each field has six (6) water cannons to meet FIH Global Certification.

Q3: Could you please confirm if the existing fields were loose laid or glued down to the elastic layer or porous asphalt?

- A3: Field #2 appears to have been loose laid over the elastic layer but was only inspected at one location. Field #1 was inspected in two locations and the turf's integral resilient backing lifted from the porous asphalt easily.
- Q4: We would need a sample of the existing elastic layer for testing. Could you please accommodate our request?
- A4: Refer to Addendum #1 for the specification for the original elastic layer.

END OF ADDENDUM #2

All Addenda will become part of the RFP Documents.
