



PURCHASING SECTION
13450 – 104 Avenue, Surrey, B.C. V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM NO. 1

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-062

TITLE: ADDITIONAL GEOTECHNICAL SERVICES
TROUTON PIT, SOUTH, WESTMINSTER ARENA

ADDENDUM ISSUE DATE: JUNE 1, 2016

REVISED CLOSING DATE: PREFER TO RECEIVE QUOTATIONS ON OR
BEFORE **JUNE 9, 2016.**

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages in total.

1. REVISED DATE:

Please note the Closing Date has been extended to June 9, 2016.

QUESTION AND ANSWERS:

Q1. In Schedule A1 it does not give a clear scope of work. Could this be clarified? Schedule A1 talks about 3 piles with end plates one in each location(NW,C,SE), the central location for the static test the reaction load is made up of at least 4 open ended piles and then states that up to 14 piles could be needed to complete the static load test. How far into the till like soil should be expected for the reaction piles? Is there any other requirements for the other two locations NW, SE?

A1. The 14 piles assumes that NO penetration into the till will be possible, and uses only the softer soils above the till for resistance – it is a worst-case scenario. Bidders should use their experience and judgement with how many ‘support’ piles are needed. We have also requested a unit rate for these piles, which can be used to adjust the contract value if more or less are required due to ground conditions.

Q2. We would like to have a site visit. It is mentioned that swamp pads may be necessary. I would like to assess this and other site conditions. We would be able to accommodate any time and dates.

A2. Site visits are permitted. Please notify us of a date and time and we will ensure access is available.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
