



PURCHASING SECTION
13450 – 104 Avenue, Surrey, -BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR PROPOSAL No.: 1220-030-2017-037

TITLE: TRAFFIC SIGNAL AND STREET LIGHT ELECTRICAL MAINTENANCE

ADDENDUM ISSUE DATE: AUGUST 18, 2017

CLOSING DATE AND TIME: ON OR BEFORE THE FOLLOWING DATE AND TIME (THE “CLOSING TIME”):

TIME: 3:00 P.M. (LOCAL TIME)

DATE: SEPTEMBER 5, 2017

INFORMATION FOR PROPONENT

Proponents are advised that Addendum No. 1 to RFP is hereby issued by the City. This addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by PROPONENT for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent or any sub-Proponent not being familiar with this addendum. This Addendum No. 1 contains two (2) pages in total.

QUESTIONS AND ANSWERS:

Q1. Please confirm if it is acceptable to provide pricing for Option 2 only or do we need to provide pricing for all three Options for the City to evaluate.

A1. The combinations listed in the RFP (Option 1, 2 and 3) are suggested delivery options only. The City encourages Proponents to propose Goods and Services delivery options that:

- Are most advantageous to the City; and**
- Are commensurate with the Proponent’s experience, personnel and equipment resources.**

The Proponent may provide pricing for option 2 only.

Q2. Are there specifications available for what is expected for the pole painting? Is wet painting with brush/roller acceptable? Is a primer coat required?

A2. The City pole inventory includes:

- Galvanized/powder coated poles;
- Galvanized/painted poles; and
- Primed/painted poles.

The application of paint is specific to the pole protective coating type and pole condition.

Galvanized/powder coated poles:

Galvanized/powder coated poles are the newest poles in the City's inventory. These poles do not require painting. Surface imperfections (i.e. rust penetration or structural damage) shall be reported to the City as part of street lighting preventative maintenance (Section 2.2).

Galvanized/painted poles and primed/painted poles:

Galvanized/painted poles and primed/painted poles shall have peeled/loose paint removed and be thoroughly cleaned prior to application of wet painting with brush/roller. Primer is not required over existing painted surfaces with good adhesion. The removal of rust, scale, or other contamination is required. A rust inhibitor (rusty metal primer) paint shall be applied over the exposed metal and finished with a wet paint colour (brush/rolled) specified by the City. Pole imperfections (i.e. rust penetration or structural damage) shall be reported to the City as part of street lighting preventative maintenance (Section 2.2).

- END OF ADDENDUM -