



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM #3

INVITATION TO TENDER (ITT) NO.: 1220-020-2018-007
TITLE: BRIDGEVIEW MINOR PAVING WORKS
ADDENDUM ISSUE DATE: January 8, 2019
TENDER CLOSING TIME: 11:00 a.m. local time
TENDER CLOSING DATE: Thursday, January 10, 2019

INFORMATION FOR TENDERERS

This Addendum is issued to provide additional information to the ITT for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the *Tenderer* not being familiar with this Addendum. This Addendum No. 3 contains one (1) page in total.

QUESTIONS AND ANSWERS:

Q1: Do you require all full depth milling areas to have base and surface lift completed prior to leaving location, or can base lift be left overnight and then the surface lift be completed the following days?

A1: Both lifts need to be done in a single day. The Contractor is to use the same UC #1 mix for both lifts.

END OF ADDENDUM #3

All Addenda will become part of the ITT Documents.
