



PURCHASING SECTION
13450 – 104 Avenue, Surrey, BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM 1

REQUEST FOR PROPOSALS (RFP) No.: 1220-030-2014-013

TITLE: SOUTH SURREY ATHLETIC PARK: SUPPLY & INSTALL SYNTHETIC TURF

ADDENDUM ISSUE DATE: May 22, 2014

CLOSING DATE AND TIME: ON OR BEFORE THE FOLLOWING DATE AND TIME (THE “CLOSING TIME”):

TIME: 3:00 P.M. (LOCAL TIME)

DATE: MAY 26, 2014

INFORMATION FOR PROPONENTS

The following information is provided to answer questions raised by Potential Proponents for the above name project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Proponent or any sub-Proponent not being familiar with this addendum. This Addendum No. 1 contains two (2) pages in total.

QUESTIONS AND ANSWERS

Q.1: P. 78 of 97 Section A.1 Performance Specifications, Part 2.4 E. states: *The grass fibre height, as measured from the top of the backing layers shall be a minimum of 60 mm or such greater height as indicated in the Technical Product Data Sheet. If a shock pad is provided, the grass fibre height may be reduced to the height indicated in the Technical Product Data Sheet.*

Could you please clarify what Technical Data Sheet is being referred to here? What minimum pile height would be acceptable over any of the approved pads?

A.1: **The Technical Data Sheet referenced in the Performance Specifications would be the one forming part of the final Agreement. Assuming a shock pad is accepted by the City, there the minimum pile height would be determined by the Proponent, considering the requirements of the RFP not specifically related to pile height (such as suitability for sport, warranty, safety, durability, etc.), and the design of the Proponent’s turf system.**

Q.2: P.70 of 97 Section A.1 Performance Specifications, Part 1.1.5 states: *Review and acceptance or certification of installed work of other trades directly affecting the Work of this Contract, especially of the gravel base as it applies to installation of turf plus Warranty implementation.*

Appendix A.2 – Form of Warranty of Synthetic Turf, does not implicate any warranting of the base. Could you please confirm that this section requires acceptance only, and no warranty on the base?

A.2: The gravel base, field drainage system, edge anchor and other aspects of the field civil work that do not form part of the Proponent's Scope of Work, are not part of the synthetic turf system Warranty.

END OF ADDENDUM

All Addenda will become part of the RFP Documents.
