



PURCHASING SECTION
13450 – 104 Avenue, Surrey, B.C. V3T 1V8
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM NO. 2

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2014-067

TITLE: SUPPLY, TESTING, COMMISSIONING AND WARRANT
OF SECONDARY UNIT SUBSTATION AT NEWTON
PUMP STATION

ADDENDUM ISSUE DATE: SEPTEMBER 25, 2014

CLOSING DATE: PREFER TO RECEIVE QUOTATIONS ON OR
BEFORE OCTOBER 2ND, 2014

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page in total.

NEW INFORMATION:

The utility metering section shall be located between the main disconnect switch and the primary side of the transformer. For primary installation, the CT compartment requires a metal floor and not to be open to concrete floor. The utility metering section on the secondary side of the transformer is no longer required.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
