



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM NO. 1

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2016-008
TITLE: SUPPLY & DELIVERY OF HEADWALLS
ADDENDUM ISSUE DATE: December 22, 2015
CLOSING DATE: prefer to receive Quotations on or before:
January 6, 2016

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 1 contains one (1) page in total.

- Q1: Item 5 on page 18 (of 19) is for 1800mm dia. pipe which will not fit into the custom lowland headwall. As the pipe o.d. would be greater than 1800mm dia. (The width of the back wall of the custom lowland head wall is only 1700mm wide).
- A1: Please supply a quote for a headwall that can accommodate the 1800 mm diameter pipe.
- Q2: The drawing shows a tapered pipe opening.
- A2: The headwalls will be equipped with a Kor N Seal gasket. Please finish the opening to be consistent with the Kor N Seal gasket requirements.
- Q3: Please clarify if we only have to quote prices on the concrete head wall c/w galvanized steel hand rail.
- A3: Please provide a quote on the concrete head wall including the Kor N Seal gasket and galvanized steel hand rail.

END OF ADDENDUM NO. 1

All Addenda will become part of the RFQ Documents.
