



**PURCHASING SECTION**  
13450 – 104 Avenue, Surrey BC V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM #2**

---

**REQUEST FOR QUOTATIONS (RFQ) NO.:** 1220-040-2016-011  
**TITLE:** CLOVERDALE CURLING RINK  
REPAIRS  
**ADDENDUM ISSUE DATE:** January 13, 2016  
**CLOSING DATE:** prefer to receive Quotations on or  
before: January 28, 2016

---

**INFORMATION FOR CONTRACTORS**

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum #2 contains two (2) pages in total.

**1. INFORMATION MEETING**

A second information meeting will be hosted by the City Representative to discuss the City's requirements under this RFQ (the "Information Meeting"). While attendance is at the discretion of Contractors, Contractors who do not attend will be deemed to have attended the Information Meeting and to have received all of the information given at the Information Meeting.

At the time of issuance of this Addendum a meeting has been schedule as follows:

Date: **January 19, 2016**

Time: 10:00 a.m. Pacific Time

Location: 6150 176th Street, Surrey, BC. Meet in Lobby

Contractors are to examine the site prior to submitting a Quotation to fully acquaint themselves with all existing conditions reasonably inferable from examination of the site and its surroundings and the RFQ and to make allowance for such conditions in the Quotation. By submitting a Quotation, a Contractor represents that it has examined the site fully as to

all conditions, contingencies, risks and circumstances, local or otherwise, which might influence or affect the performance or the cost of the work, including but not limited to: location of the work, location of buildings on the site, adjacent properties, Contractor occupancy during the work, access and all other conditions that a competent Contractor experienced in work similar to the work would consider and take into account, and is further deemed to have included in the contract price all costs occasioned thereby.

## **2. QUESTIONS AND ANSWERS**

Q1: How much of the exterior of the building is to be painted after piling work is completed?

**A1: The entire wall of affected areas are to be painted.**

Q2: How much of the interior of the building is to be painted after piling work is completed (Stairwell and backside of upper header block work)?

**A2: The entire wall of affected areas are to be painted.**

Q3: Is gas to be permanently or temporary relocated?

**A3: Gas is to be temporary relocated.**

Q4: Is excavation to be stockpiled and reused as required or removed from site?

**A4: Excavation is to be removed from site, replace with structural fill material.**

Q5: Can Stairs be stored onsite?

**A5: Yes.**

Q6: Will the slab jacking will be dealt with as CO?

**A6: No.**

Q7: Is a building permit required?

**A7: The City of Surrey is responsible for the building permit.**

**END OF ADDENDUM #2**

---

**All Addenda will become part of the RFQ Documents.**

---