



PURCHASING SECTION
6645 – 148th Street, Surrey, B.C. V3S 3C7
Tel: 604-590-7274 Fax: 604-599-0956
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2013-026

TITLE: REPLACE BOILER AT SURREY ARTS CENTRE

ADDENDUM ISSUE DATE: MAY 13, 2013

DATE: PREFER TO RECEIVE QUOTATIONS ON OR
BEFORE MAY 15, 2013

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information and clarifications to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page in total.

1. REFER TO SPECIFICATIONS – CONTROL SEQUENCES, SECTION 15970

Section 4. - CONTROL SEQUENCES, item 4.1. Boilers Hydronic Heating System Loop,
.2 Primary Hydronic Heating Water Loop:

DELETE:

- .1 In general, boilers are to come with fully compatible Bacnet Interface connected to existing DDC network for control and monitoring purposes as well as full boiler diagnostics reporting, complete with DDC graphics. If Owner supplied boiler does not come with Bacnet Interface. Control contractor is to provide in his price supply and installation of Bacnet Interface.

SUBSTITUTE:

- .1 the boilers are to be hard-wired with no BACnet interface.

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
