



**PURCHASING SECTION**  
13450 – 104 Avenue, Surrey BC V3T 1V8  
Tel: 604-590-7274

E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM #1**

---

**REQUEST FOR QUOTATIONS (RFQ) NO.:** 1220-040-2019-002  
**TITLE:** SUPPLY AND DELIVERY OF EARTHQUAKE RESISTANT DUCTILE IRON PIPE  
**ADDENDUM ISSUE DATE:** January 31, 2019  
**CLOSING DATE:** prefer to receive Quotations on or before:  
February 12, 2019

---

**INFORMATION FOR CONTRACTORS**

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 1 contains two (2) pages in total.

**CLARIFICATION:**

The size of pipe required is 300mm.

**QUESTIONS AND ANSWERS:**

Q1: Is Zinc Coating required?

A1: Yes, anti-corrosion coating is required.

Q2: Is Polyethylene Encasement required?

A2: Not at this time.

Q3: Can you confirm that the base pipe required is minimum Pressure Class 350 to AWWA C151 and is Cement Mortar Lined to AWWA C104.

A3: The minimum Pressure Class is 350, AWWA C151, and AWWA C104 or JWWA A113.

Q4: Are fittings and valves required?

A4: No.

**END OF ADDENDUM #1**

---

---

**All Addenda will become part of the RFQ Documents.**

---

---