



**PURCHASING SECTION**  
13450 – 104 Avenue, Surrey, BC V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM No. 2**

---

**INVITATION TO TENDER No.:** 1220-020-2018-005

**TITLE:** SURREY RCMP MAIN DETACHMENT  
INTERIOR RENOVATIONS

**ADDENDUM ISSUE DATE:** AUGUST 28, 2018

**REVISED CLOSING DATE:** On or before the following date and time:

**Time:** 11:00 a.m., local time

**Date:** Thursday, August 30, 2018

---

**INFORMATION FOR CONTRACTORS**

Tenderers are advised that Addendum No. 2 to ITT 1220-020-2018-005 is hereby issued by the City. This addendum shall form part of the Contract Documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Tenderers for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the *Tenderer* not being familiar with this Addendum. This Addendum No. 2 contains two (2) pages in total.

**QUESTIONS & ANSWERS**

**Q1:** In Part C Form of Tender Appendix 1 it lists Phase 1 as areas 1A, 1B, 2B, then I item # 5 it references Area 3, 4, & 5. In the tender drawings E4.01 detail 2 there is an area 2C. Which item in the Appendix 1 should this be included in?

**A1:** Area 2C is actually Area 2B; please include in Phase 1.

**Q2:** On drawing E0.05 details 1 & 2 depict consolidation points with 24 cables; on E4.02 Area 4 depicts 1 CP but there are 34 cables in this area. Should we allow for an additional CP?

**A2:** Please allow for additional CP in Area 4.

Q3: There is a bit of a mix up on the carpet spec.  
'On Line' is a carpet tile that comes in 25cm x 100cm  
"CT102' is a carpet tile that comes in 50cm x 50cm

CT102 is not a color as stated in the specification. Please clarify what material out of the two I should use for my quotation as there is a minor price difference between the two.

**A3: Carpet as per spec: Interface Series CT102 or approved alternate, 500mm x 500mm, colour: "Onyx".**

**- END OF ADDENDUM -**

---

**All Addenda will become part of the ITT Documents.**

---