



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATIONS No.: 1220-040-2021-038

TITLE: BOILER REPLACEMENT – NEWTON WAVE POOL

ADDENDUM ISSUE DATE: MAY 19, 2021

REVISED DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE MAY 27, 2021.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2021-038 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

CLARIFICATIONS:

1. **SPECIFICATION – MECHANICAL**
 - .1 **Clarification:**
 - .1 **All joints in piping system must be welded or screwed fittings. Victaulic/grooved couplings are not permitted.**
2. **Contractor to have a cash allowance of \$10,000 for final commissioning of the system. This is to allow for a subsequent commissioning of the system once the facility is back at full capacity (i.e., pools are filled). The date for when the facility will be back at full capacity is currently unknown as it depends on when COVID restrictions are lifted/relaxed.**

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -