



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATIONS No.: 1220-040-2021-074

TITLE: SUPPLY AND DELIVERY OF PIPES AND FITTINGS
FOR WATERMAIN

ADDENDUM ISSUE DATE: OCTOBER 27, 2021

CLOSING DATE: PREFER TO RECEIVE SUBMISSION ON OR
BEFORE OCTOBER 28, 2021

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2021-074 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. Star Pipe product Restraint (series 3000) was approved by the City of Surrey on October 8th, 2020 to be included on the next City of Surrey approved product update. Please advise if this Star Pipe restraint approval will be considered for this RFQ response as Surrey has not updated standards since this question was sent.

A1. The Star Pipe restraints are only approved for pipe up to 350mm in diameter.

Q2. Please advise the PSI rating of the water design.

A2. The pipe is to be pressure class 350 ductile iron.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -