



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 1

---

REQUEST FOR QUOTATION No.: SUPPLY AND DELIVERY OF PIPES AND FITTINGS  
FOR WATER MAIN AND SANITARY SEWER MAIN  
PROJECTS

TITLE: 1220-040-2021-090

ADDENDUM ISSUE DATE: DECEMBER 9, 2021

DATE: PREFER TO RECEIVE SUBMISSION ON OR  
BEFORE DECEMBER 16, 2021.

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2021-090 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains two (2) pages.

### QUESTIONS AND ANSWERS:

- Q1. Quotation 1: Project W-16641: Are items 3 & 4 the same part? MJ 300mm restrained gland packs?
- A1. Item 3 is pipe restraint with gland pack, item 4 is restraint without gland pack.
- Q2. Quotation 1: Project W-16641: Items 6 & 7 are the same fitting just with different quantities?
- A2. Item 7 should be 150 mm FI x H Adapter.
- Q3. Quotation 1: Project W-16641: Are the couplings, items 9 through 12 are to be standard “non restrained” couplings?
- A3. Items 9 and 10 (350mm and 300mm couplers) are to be restrained coupling. Items 11 and 12 are standard non restrained
- Q4. Quotation 3: Project W-11556: Are the couplings, items 6 & 7 to be standard “non restrained” couplings?

**A4. Couplings are to be restrained.**

**Q5. Quotation 4: Project W-13873: Are items 4 & 5 the same part? MJ 300mm restrained gland packs?**

**A5. Item 4 is pipe restraint with gland pack, item 5 is restraint without gland pack.**

---

All Addenda will become part of the Contract Documents.

---

- END OF ADDENDUM -