



**PROCUREMENT SERVICES**

**CITY OF SURREY, SURREY CITY HALL**  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM No. 2**

---

**REQUEST FOR QUOTATION No.:**      **SUPPLY AND DELIVERY OF PIPES AND FITTINGS  
FOR WATER MAIN AND SANITARY SEWER MAIN  
PROJECTS**

**TITLE:**                                    **1220-040-2021-090**

**ADDENDUM ISSUE DATE:**        **DECEMBER 14, 2021**

**DATE:**                                    **PREFER TO RECEIVE SUBMISSION ON OR  
BEFORE DECEMBER 16, 2021.**

---

**INFORMATION FOR CONTRACTORS**

Contractors are advised that Addendum No. 2 to 1220-040-2021-090 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

**QUESTIONS AND ANSWERS:**

**Q1.      Please confirm what kind of pipe the 350mm Robar Restrained cplg from Project #W-11556 is going onto. Because there is no 350mm pipe on the RFQ to determine this?**

**A1.      The 350mm will be for a tie in to existing ductile iron pipe.**

---

**All Addenda will become part of the Contract Documents.**

---

**- END OF ADDENDUM -**