



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATIONS No.: 1220-040-2022-011

TITLE: Supply and Delivery of Pipes for Flood Boxes

ADDENDUM ISSUE DATE: February 1st, 2022

DATE: PREFER TO RECEIVE SUBMISSION ON OR
BEFORE FEBRUARY 9TH, 2022.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No.1 to RFQ # 1220-040-2022-011 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No.1 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. The City of Surrey is specifying AASHTO Class IV classification for the embedment material, as well as AASHTO H20 live load. Does the City also require the design to be done using AASHTO design methodology? Please advise.

A1. The City does require the design to be done using AASHTO design methodology.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -