



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 2

REQUEST FOR QUOTATIONS No.: 1220-040-2022-011

TITLE: Supply and Delivery of Pipes for Flood Boxes

ADDENDUM ISSUE DATE: February 3, 2022

DATE: PREFER TO RECEIVE SUBMISSION ON OR
BEFORE February 9, 2022.

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No.2 to RFQ # 1220-040-2022-011 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No.2 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. Since Covid, we have trouble getting any aluminum coil. Would you consider the Aluminized Type 2 coil for the CSP? We have been getting this coil and making CSP out of it. Please advise?

A1. The City will accept the Aluminized Type 2 coil for the CSP.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -