



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 1

REQUEST FOR QUOTATION No.:	1220-040-2022-038
TITLE:	JOINT RESTRAINTS FOR WATERMAIN
ADDENDUM ISSUE DATE:	APRIL 5, 2022
DATE:	PREFER TO RECEIVE SUBMISSION ON OR BEFORE APRIL 7

INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2022-038 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors, for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains one (1) page.

QUESTIONS AND ANSWERS:

- Q1. What type of pipe are the restraints being used on (DI, C900, C909 Bionax, Etc.)?
- A1. The type of pipe that the restraints are used on is DI.
- Q2. Are the restraints to be tandem for ERDIP or standard pipe?
- A2. The restraints are Singles.
- Q3. What width size of Petro Tape is required? 2", 4" 6" are all available.
- A3. The width size is 6".

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -