



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 1

---

REQUEST FOR QUOTATION No.: 1220-040-2022-040

TITLE: SUN SHADE STRUCTURES

ADDENDUM ISSUE DATE: JULY 25, 2022

**REVISED DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE AUGUST 4, 2022**

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 1 to 1220-040-2022-040 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 1 contains three (3) pages.

### QUESTIONS AND ANSWERS:

**Q1. Will inground mounting installation be possible at Guildford Recreation Centre?**

**A1. Yes**

**Q2. What is the size of the unit required for Chuck Bailey Recreation Centre?**

**A2. Not yet determined as Chuck Bailey is under construction. This will be provided later.**


**Q3. Can you please clarify what is meant by free-standing unit?**

**A3. Not attached to any component of the envelope of the building, standing on its own in ground.**

**Q4.** If the slope is incorrect (and collecting water) at South Surrey Recreation & Arts Centre, its assumed we would need to adjust the structures mounting posts, while also replacing the shade. Can you provide more images of the current shade structure?

**A4.** If it is a sun shade the water drips through regardless of the angle . It does pool a bit in the middle and drip quite a bit through there. Snow does collect in the middle and with the melt and rain factor it can weigh it down considerably.

**Yes to replacing shade.**



**Q5.** Do you have measurements or as built drawings for the current shade at South Surrey Recreation & Arts Centre?

**A5.** No, drawings are not available.

Q6. With the replacement of the existing shade at South Surrey what color is desired? Similar to the existing color?

A6. **Similar to existing.**

Q7. What is the size, color of shade sail, and mounting style is required at Kensington Prairie Community Centre?

A7. **Black, 10X12.**

Q8. Is the intention at the Fleetwood Community Centre to have a shade sail with inground posts?

A8. **Yes, with in ground posts.**

Q9. What color of shade sail is required at Fleetwood Community Centre?

A9. **Black.**

Q10. What color of sail is desired at the Surrey Nature Centre?

A10. **Black.**

Q11. Has there been prior consultations on product feasibility, specs and timelines previous to the RFQ? We are curious as to how this spec was developed as it is not typically what we see for standard offerings. Is this specific to one manufacturer?

A11. **No, not specific from one manufacturer. Information collected by staff are from previous various projects.**

Q12. For #6 South Surrey that shade sail is the manufacturer we work with. If the concern is waterpooling that can be adjusted with height variations, however if you want it to be waterproof that will require a new design. Please advise.

A12. **Concern is with water pooling only, height variations are needed only.**

Q13. It states that shade fabric should be designed for four seasons with identified wind and snow loads and be water-resistant.(1.1.2 c and d) Later on in the specifications it states that shade fabric should be waterproof (1.1.2 h).

You are unable to use shade fabric for waterproof and snow loading. We can provide waterproof shade fabric but not for snow loading – it would be 3 seasons.

We can provide waterproof and snow loading but that would require vinyl not shade fabric.

It also states that you are looking for 100% monofilament yarn with no tape or filler in yarn. This is available but is not waterproof.

We can provide what you want but would just like clarification on the requirements as there is more than one requirement at the moment.

A13. **We are looking to use for all seasons.**

---

---

All Addenda will become part of the Contract Documents.