



PROCUREMENT SERVICES  
CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8

Tel: 604-590-7274

E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

**ADDENDUM #2**

---

REQUEST FOR QUOTATIONS (RFQ) No.:	1220-040-2022-055
TITLE:	FIRE PANEL REPLACEMENT - SURREY ARTS CENTRE
ADDENDUM ISSUE DATE:	MAY 20, 2022
DATE:	prefer to receive Quotations on or before May 31, 2022

---

**INFORMATION FOR CONTRACTORS**

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum.

**1. CLARIFICATION – HEAT DETECTOR ACCESS**

Surrey Arts Center FA Upgrade

As per site information meeting. During the site walk through it was discovered that some of the conventional detectors that need to be replaced in the theater are in locations that will be difficult to access. Contractors are responsible to include the cost of access in their Quotation. Keeping in mind that the stage structure below the detectors can not bare much weight, there for a lift will not be permitted.

**- END OF ADDENDUM -**

---

**All Addenda will become part of the RFQ Documents.**

---