



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM NO. 3

REQUEST FOR QUOTATIONS (RFQ) NO.: 1220-040-2019-032
TITLE: CLOVERDALE CURLING RINK STAIR RENOVATION
ADDENDUM ISSUE DATE: JUNE 4, 2019
CLOSING DATE AND TIME: PREFER TO RECEIVE QUOTATIONS ON OR BEFORE JUNE 5, 2019.

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 3 contains only one (1) page.

Q1: Please confirm the paint system required for the stairs and the railings (i.e. SP-6 Prep & one coat Primer or SP-3 prep to CISC/CPMA 1-73a)?

**A1: Paint for doors, door frames, stair and stair rails
Exterior Acrylic Semi-Gloss Latex**

**Paint for walls trim, inside stair:
INTERIOR PREMIUM GRADE LATEX EGGSHELL PAINT**

**Exterior trim & metal:
Exterior Acrylic Semi-Gloss Latex.**

END OF ADDENDUM

All Addenda will become part of the RFQ Documents.
