



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca
ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) NO.:	1220-040-2018-056
TITLE:	PREVENTATIVE MAINTENANCE SERVICING OF STANDBY POWER UNITS
ADDENDUM ISSUE DATE:	April 4, 2019
CLOSING DATE:	prefer to receive Quotations on or before: April 5, 2019

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains one (1) page in total.

QUESTIONS AND ANSWERS:

- Q1: Section 2.1.1 sub (n)
Start & run generator. How long do you want us to run the generator per month?
- A1: The City estimates this may take one (1) hour but the Contractor should provide their recommendation.
- Q2: Section 2.1.1 sub (o)
Exercise transfer switch. Do you mean doing a transfer test and run it for an hour? Or just to make sure it transfers?
- A2: The transfer switches need to be tested to ensure they operate in an emergency power outage.
- Q3: For the three “afterhours” units, what is the earliest time we can come to site for the respective services?
- A3: These would generally be done on weekends or after 6:00 PM, site dependent working around operational requirements which vary from location to location.

END OF ADDENDUM #2

All Addenda will become part of the RFQ Documents.
