



PURCHASING SECTION
13450 – 104 Avenue, Surrey BC V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM #2

REQUEST FOR QUOTATIONS (RFQ) NO.:	1220-040-2019-020
TITLE:	SUPPLY AND INSTALLATION OF EVAPORATIVE CONDENSER - SOUTH SURREY ARENA
ADDENDUM ISSUE DATE:	May 22, 2019
REVISED CLOSING DATE:	prefer to receive Quotations on or before: May 28, 2019

INFORMATION FOR CONTRACTORS

This Addendum is issued to provide additional information to the RFQ for the above named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractor not being familiar with this Addendum. This Addendum No. 2 contains two (2) pages in total.

REVISED CLOSING DATE:

The City would prefer to receive Quotations on or before **Tuesday, May 28, 2019**. The City's office hours are 8:30 a.m. to 4:00 p.m., Monday to Friday, except statutory holidays.

**CLARIFICATIONS/ REVISIONS TO THE SUPPLEMENTARY SPECIFICATIONS (PROJECT)
AND CONTRACT DRAWINGS (PROJECT):**

- 1) The condenser size for selection is revised to:

Operating conditions: 90 °F saturated discharge temperature
68 °F wet bulb temperature
10 °F saturated suction temperature

- 2) The new condenser is to be selected to match the existing base. Any modifications to the base for the new condenser are to be included in the Contractor's Total Quotation Price.
- 3) All installation work for the new condenser is to be completed while the rink is in operation. Any overtime required for this work is to be included in the Contractor's Total Quotation Price.
- 4) The access ladder and the oversized drain in the specification are to be deleted from the Supplementary Specifications (Project) and Contract Drawings (Project). Access for servicing for the condenser will be overhead from the grate modifications listed in Addendum #2.

END OF ADDENDUM #2

All Addenda will become part of the RFQ Documents.
