



PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL
13450 – 104 Avenue, Surrey, B.C., V3T 1V8
Tel: 604-590-7274
E-mail: purchasing@surrey.ca

ADDENDUM No. 4

INVITATION TO TENDERERS No.: 1220-020-2023-003

TITLE: GUILDFORD RECREATION CENTRE ROOF
REPLACEMENT

ADDENDUM ISSUE DATE: JUNE 14, 2023

**REVISED CLOSING DATE AND TIME: ON OR BEFORE THE FOLLOWING DATE AND
TIME (THE "CLOSING TIME"):**

TIME: 11:00 A.M. (LOCAL TIME)

DATE: JUNE 16, 2023

INFORMATION FOR TENDERERS

Tenderers are advised that Addendum No. 4 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Tenderers for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Tenderers or any sub-contractor not being familiar with this addendum. This Addendum No. 4 contains one (1) page.

QUESTIONS AND ANSWERS:

Q1. Should roofers re-use the existing snowguards or allow for all new snowguards for the whole job?

A1. Re-use existing snowguards on the north-west side. New ones on the south-west and south-east sides.

Q2. Can you confirm whether fully-sloped taper package is required for any/all of the separate price lower roofs?

A2. The cut test reflects that the flat roof decking provides slope. At the parapet, no taper package was found during cut test. Large crickets are required in some sections of the roof to provide slope to drain.

All Addenda will become part of the Contract Documents.

- END OF ADDENDUM -