



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 2

---

REQUEST FOR QUOTATION No.: 1220-040-2023-014

TITLE: West Village Energy Centre – Hot Water Boilers

ADDENDUM ISSUE DATE: March 29, 2023

DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE APRIL 5, 2023.

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2023-014 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

### QUESTIONS AND ANSWERS:

- Q1.** Would a mesh burner be acceptable to meet the 20 mg/m<sup>3</sup> NO<sub>x</sub> requirements?
- A1.** **We would consider any burner technology. We would expect the Contractor to be able to demonstrate that the proposed technology has a proven record of successful operation in applications that are similar to what is required for this project.**

---

All Addenda will become part of the Contract Documents.

---

- END OF ADDENDUM -