



## PROCUREMENT SERVICES

CITY OF SURREY, SURREY CITY HALL  
13450 – 104 Avenue, Surrey, B.C., V3T 1V8  
Tel: 604-590-7274  
E-mail: [purchasing@surrey.ca](mailto:purchasing@surrey.ca)

### ADDENDUM No. 2

---

REQUEST FOR QUOTATION No.: 1220-040-2023-067

TITLE: INSTALLATION SERVICES, LED FIXTURES

ADDENDUM ISSUE DATE: November 6, 2023

DATE: PREFER TO RECEIVE SUBMISSION ON OR BEFORE NOVEMBER 8, 2023.

---

### INFORMATION FOR CONTRACTORS

Contractors are advised that Addendum No. 2 to 1220-040-2023-067 is hereby issued by the City. This addendum shall form part of the contract documents and is to be read, interpreted and coordinated with all other parts. The following information is provided to answer questions raised by Contractors for the above-named project, to the extent referenced and shall become a part thereof. No consideration will be allowed for extras due to the Contractors or any sub-contractor not being familiar with this addendum. This Addendum No. 2 contains one (1) page.

### QUESTIONS AND ANSWERS:

- Q1.** Could you please confirm which type of tenon is required?
- A1.** Tenon adaptor to slip over existing 3 ½ inch OD tenon. C/W new top 2 3/8 inch OD tenon. Powder Coated RAL 7040. Adaptor shall meet CAN/CSA S6-14-Canadian Highway Bridge Design Code.

---

All Addenda will become part of the Contract Documents.

---

- END OF ADDENDUM -